

**Attachment 1**  
**Summary of Permit Changes**

(minor/non-technical changes are not included in this summary)

1. Section F, Permit limits and conditions. The Maximum Hydraulic Loading Rate for the Non-growing Season was revised to include a maximum loading rate of 5.9 inches total as a result of shallow bedrock and soil conditions. This change was made to be consistent with the staff analysis dated May 7, 2004.
2. Section F, Permit limits and conditions. The SBR treatment system effluent limit for total nitrogen, along with the associated note, was deleted. This item is addressed as part of the SBR treatment system and is covered in the Agreement Regarding Approval of Plans and Specifications between DEQ and Arbor Ridge LLC issued in December 2004.
3. Section G, Monitoring Requirements. The requirement for daily Meteorological Data and Field Conditions was deleted as this item will no longer be required at this site.